



Invisible Service Technician

Dramatically Reduce Your Heating & Cooling Costs!

Manufacturer Rep Support



Manufacturer Rep Support

Distributor Support

Contractor Support

Profile Management

Data Center

IST Monitor Activation

Customer:
IST Monitor ID:

Active Monitors

Unassigned Monitors

Inactive Monitors

Monitor Details

Monitor Report

Monitor Report

◀ [Prev](#) [Next](#) ▶ [Show Most Recent](#)

Number of transmission retries: 0
Number of power fails ignored: 0

Sensor Key: ● = Enabled ◻ = Not Installed ◻ = Disabled Status Key: ✓ = Ok ✗ = Fault

(Temperatures in Fahrenheit)

Report Date
02/18/2006 05:29:02 (ET)
Type: Scheduled - Last Steady State

Previous Report Date
02/16/2006 05:29:02 (ET)
Type: Scheduled - Last Steady State

Parameters	Reported Value	Min Value	Max Value	Lower Limit	Upper Limit	Status	Reported Value	Min Value	Max Value	Status
● Suction Line Temperature	14	14	34	N/A	N/A	✓	27	23	61	✓
● Liquid Line Temperature	61	30	65	N/A	N/A	✓	70	51	76	✓
● Evaporator Supply Air Temperature	-11	-13	23	N/A	N/A	✓	-10	-15	26	✓
● Box Temperature	0	-6	34	-15	15	✗	12	-10	31	✗

	Status	Previous Status
● System Power	✓	✓
◻ N/A	✓	✓
● Door Switch-Door Open: Switch=closed	✓	✓
● Evaporator Pan Water Level	✓	✓
● Compressor Status	✓	✓
◻ N/A	✓	✓
● Backup Power Supply Reader FLASHES: LED is On	✓	✓
◻ N/A	✓	✓
◻ N/A	✓	✓

Enough data is reported to enable a remote diagnosis of the problem.

The data is protected and is only accessible via a unique username and password.

	Reporting Cycle Totals	Condition at Time of Report	Previous Cycle Totals	Condition at Time of Previous Report
Fan Minutes	0	OFF	0	OFF
Cool1 Minutes	1171	ON	1439	ON
Cool2 Minutes	0	OFF	0	OFF
Heat1 Minutes	0	OFF	0	OFF
Heat2 Minutes	0	OFF	0	OFF
Reverse Valve Minutes	0	OFF	0	OFF
Freeze Door Minutes Opened	1053	OFF	1384	OFF
Aux 3 Minutes	0	OFF	0	OFF
Fan Cycle	0	OFF	0	OFF
Heating Degree Days	0	—	0	—
Cooling Degree Days	0	—	0	—